

Message

From: Tom Lloyd [tlloyd@sprung.com]
Sent: 9/5/2019 5:27:46 PM
To: Mel Milanovic [mmilanovic@collingwood.ca]
Subject: Re: Centennial Aquatic Centre

EXTERNAL EMAIL: This email originated outside of the Town's email system. Do not click any links or open any attachments unless you trust the sender and know the content is safe. If in doubt, please contact the helpdesk at x4357.

Hi Mel,

I spoke to BLT and they are looking into this. As you know the Collingwood Inquiry is starting next week so timing is not great.

Have a great evening.

Cheers,

Tom

Tom Lloyd
Regional Business Development Manager
Sprung Structures
12 Upjohn Road, Unit 4 M3B 1Y2
Toronto, ON
O: 905.829.1600
C: 416.818.9458

From: Mel Milanovic <mmilanovic@collingwood.ca>
Sent: Thursday, September 5, 2019 1:59 PM
To: Tom Lloyd <tlloyd@sprung.com>; Dave Barrow <dave@bltconstruction.com>; Paul Waddell <pwaddell@bltconstruction.com>
Cc: Dean Collver <dcollver@collingwood.ca>
Subject: Centennial Aquatic Centre

Gentlemen ,

We have started the process to re-tiling the change rooms at the pool and wanted to show you what we found. Not sure who you used to set the tiles, but the quality of workmanship is very poor as you can see in the pictures below. Wrong materials were used, there was no waterproofing, adhesives were incorrect, floors were not sloped at all toward the drains, the type of tile is not correct for this application and not enough floor drains were installed for these areas.


Our facilities are your flag ship buildings when it comes to arenas and pools. The groups that I tour through these facilities or that call to enquire about them are asking about the quality of workmanship and the longevity of materials used. I think you need to take a long, hard look at what went on here. We will have spent just over \$400,000 in the last three years correcting issues that should never have needed correcting.

Regards,






















Mel Milanovic, CRFP, CIT, CPT, CAT, CPO
Manager of Recreation Facilities, PRC Department
705-444-2500 Ext. 3239
705-446-6402
mmilanovic@collingwood.ca

This transmission may contain information that is subject to or exempt from disclosure pursuant to the Municipal Freedom of Information and Protection of Privacy Act and other applicable law. The information contained in and/or attached to this transmission is intended solely for the intended recipient. If you are not the intended recipient, you are hereby notified that any disclosure, photocopying, distribution, or dissemination of the contents, in whole or in part, is unauthorized and prohibited. If you have received this transmission in error, please notify the sender immediately and destroy all copies